

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE.**

No. 26

Date : 16/11/2026

It is certified that an inspection team headed by Shyam Kumar Doley
AE PHED (Name of Officers with designation) from
PHED, Badi (Name of Department/Office)
inspected the BEERSHEBA INTERNATIONAL SCHOOL on 11/02/26 and
found that the BEERSHEBA INTERNATIONAL SCHOOL has safe drinking water
facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the
norms prescribed by the State Govt.

The above valid for a period of 11/02/27.

Signature with Seal
Name
Designation


Assistant Engineer,
Public Health Engineering,
Sub-Division Badi.
M

To
BEERSHEBA
INTERNATIONAL SCHOOL
BADI, RAISEN
(Name & Address of the Institution)


Results of the samples

DISTRICT

Senders letter no :-		Senders letter Date:-		Date of analysis:- 11.02.2026			Sub Division Lab Ref No. ----			Date of analysis completed :- 11.02.2026			Unique ID No. -----			
No.	Parameters/units															
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1	Iron in Mg/l	0.5														
2	Nitrate in Mg/l	0.0														
3	Fluoride in Mg/l	00														
4	Chloride in Mg/l	71														
5	Alkalinity in Mg/l	548														
6	Calcium In Mg/l	-														
7	Magnesium in Mg/l	-														
8	Manganese in Mg/l	-														
9	pH on pH scale	7.5														
10	Turbidity in NTU	4.1														
11	Hardness in Mg/l	376														
12	Conductivity uS/cm	1118														
13	TDS by meter	661														
14	Arsenic	0.00														
15	Faecal Coliform (TTC)	0.00														

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under acceptable render not suitable but still may be tolerated in the alternative source but up to limits indicated under the permissible limit in the absence source in column 6 above which the source will have rejected.
3. The results refer only to tested samples and parameters tested.
4. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
5. The tests marked with not accredited by NABL

The given sample is found free from the contamination for the tested parameters.


 रसायन
 जल परीक्षण प्रयोगशाला
 लोक स्वास्थ्य यांत्रिकी विभाग
 उपरमण्ड-बाही